

Zał. V1. Zestawienie ilości powietrza wentylacyjnego

Nr	Nazwa	Powierzchnia [m ²]	Wysokość [m]	Kubatura [m ³]	Ilość osób	Krotność wymian powietrza [1/h]	Ilość pow. naw. [m ³ /h]	Ilość pow. wyw. [m ³ /h]	Układ went. nawiew.	Układ wenty. wywiewny
	PIWNICA									
-1.01	Komunikacja	24,51	2,8	68,6		0,5	30	30	N1	WD5
-1.02.1	magazyn	19,65	2,8	55,0		1,0	50	50	N1	WD5
-1.02.2	Magazyn	10,2	2,8	28,6		1,0	20	20	N1	WD5
-1.03	Rozdzielnia elektryczna	6,96	2,8	19,5		1,5	20	20	N1	WD5
-1.05	Magazyn	14,14	2,7	38,2		1,0	30	30	N1	WD5
-1.06	Łazienka	4,65	2,7	12,6		1,0	KK	80	KK	WD6
-1.07	Magazyn	4,65	2,7	12,6		1,0	KK	15	KK	WD5
-1.13	Pomieszczenie	21,22	2,7	57,3		1,0	50	50	N3	WD3
-1.14	Pomieszczenie	10,8	2,7	29,2		1,0	30	30	N3	WD3
-1.19	Magazyn	31,99	2,7	86,4		0,7	KK	50	N1	WD5
	PARTER									
0.01	klatka schodowa	53,5	3,0	160,5			graw	graw	graw	graw
0.02	Rejestracja	25,82	3,0	77,5	4	2,0	150	150	N1	W1
0.03	Rejestracja telefoniczna	8,33	3,0	24,99		2	50	50	N1	W1
0.04	wiatrołap	9,48	3,0	28,4	6	2,0	graw	graw	graw	graw
0.05	Gabinet nefrologiczny	13,44	3,0	40,3	2	2,5	110	110	N1	W1
0.06	Chirurgia ogólna	13,81	3,0	41,4	2	2,5	110	110	N1	W1
0.07	Chirurgia zabiegowy	17,53	3,0	52,6	2	5,0	260	250	N1	W1
0.08	Gabinet neurochirurgii	12,08	3,0	36,2	2	2,5	100	100	N1	W1
0.09	Chirurgia zabiegowy	16,46	3,0	49,4	2	5,0	260	250	N1	W1
0.10	Chirurgia naczyniowa	14,84	3,0	44,5	3	2,5	120	120	N1	W1
0.11	Rejestracja – Medycyna pracy	14,84	3,0	44,5	3	2,5	120	120	N1	W1
0.12	Gabinet lekarski – Medycyna pracy	12,96	3,0	38,9	2	2,5	100	100	N1	W1
0.13	Gabinet lekarski – Medycyna pracy	12,48	3,0	37,4	2	2,5	100	100	N1	W1
0.14	Klatka schodowa	19,34	3	58,02			graw	graw	graw	graw
0.15	Brudownik	4,08	3,0	12,2		5,0	KK	70	KK	WD2
0.16	Pom. porządkowe	6,55	3,0	19,7	4	2,0	KK	30	KK	WD2
0.17	Pom. socjalne	13,15	3,0	39,5		3,0	130	130	N1	WD1
0.18	Pom. do karmienia	10,39	3,0	31,2		3,0	KK	100	N1	WD2
0.19	Szatnia damska	10,93	3,0	32,8		4,5	160	KK	N1	KK
0.20	Łazienka	4,83	3,0	14,5		9,0	KK	130	KK	WD2
0.21	WC	2,06	3,0	6,2		7,0	KK	50	KK	WD2

0.22	Łazienka	1,87	3,0	5,6		9,0	KK	50	KK	WD2
0.23	WC	2,2	3,0	6,6		7,0	KK	50	KK	WD2
0.24	Szatnia męska	8,75	3,0	26,3		4,0	110	KK	N1	KK
0.25	Łazienka	3,51	3,0	10,5		4,0	KK	50	KK	WD2
0.26	WC	1,92	3,0	5,8		5,0	KK	30	KK	WD2
0.27	WC	1,85	3,0	5,6		8,0	KK	50	KK	WD2
0.28	Komunikacja	98,33	3,0	295,0		2,5	1030	800	N1	W1
0.29	toaleta damska	8,75	2,5	21,9		4,0	KK	80	KK	WD6
0.30	toaleta męska	3,9	2,5	9,8		4,0	KK	KK	KK	KK
0.31	WC	1,44	2,5	3,6		7	KK	30	KK	WD6
0.32	WC	1,57	2,5	3,9		11,0	KK	50	KK	WD6
0.33	magazyn	10,52	2,5	26,3		1,0	KK	30	N1	WD1
0.42	Pokój socjalny pacjentów	13,22	2,7	35,7		1,5	60	60	N3	W3
0.43	Szatnia	12,72	2,7	34,3		4,1	150	150	N4	WD4
0.49	Komfortka	16,24	2,5	40,6		3,0	110	120	N1	WD6
0.50	Archiwum	14,25	2,5	35,6		1,0	30	30	N1	WD1
	1 PIĘTRO									
1.01	Komunikacja	53,22	3,0	159,7			graw	graw	graw	graw
1.02	Komunikacja	94,68	2,5	232,0	62	4,3	1020	990	N1	W1
1.03	Gabinet lekarski - P. laryngologiczna	12,35	3,0	37,1	2	2,5	100	100	N1	W1
1.04	Gabinet lekarski - P. laryngologiczna	12,33	3,0	37,0	2	2,5	100	100	N1	W1
1.05	Gabinet lekarski - P. laryngologiczna	15,98	3,0	47,9	2	2,5	120	120	N1	W1
1.06	Gabinet lekarski - P. laryngologiczna	15,11	3,0	45,3	2	2,5	110	110	N1	W1
1.07	Gabinet okulistyyczny	12,83	3,0	38,5	2	2,5	100	100	N1	W1
1.08	Ciemnia	14,54	3,0	43,6	2	2,5	110	110	N1	W1
1.09	Gabinet okulistyyczny	12,69	3,0	38,1	4	2,5	100	100	N1	W1
1.10	Gabinet okulistyyczny	16,44	3,0	49,3	2	2,5	130	130	N1	W1
1.11	Statystyka	16,46	3,0	49,4	2	2,5	130	130	N1	W1
1.12	Pokój kierownika	14,84	3,0	44,5	2	2,5	120	120	N1	W1
1.13	Pokój p. koordynującej	14,84	3,0	44,5	2	2,5	120	120	N1	W1
1.14	Sala szkoleń	26,37	3,0	79,1	22	8,3	660	660	N2	W2
1.15	Klatka schodowa	30,33	3,0	91,0		1,0	graw	graw	graw	graw
1.16	Gabinet lekarski – Plamka żółta	17,38	3,0	52,1	2	2,5	140	140	N1	W1
1.17	Gabinet zabiegowy – Plamka żółta	18,14	3,0	54,4	2	5,0	260	250	N1	W1
1.18	Łazienka personelu	4,75	2,5	11,9		5,0	KK	KK	KK	KK
1.19	WC	1,51	2,5	3,8		13,0	KK	50	KK	WD2
1.20	Łazienka personelu	3,55	2,5	8,9		9,0	KK	KK	KK	KK
1.21	WC	1,98	2,5	5,0		6,0	KK	30	KK	WD2

1.22	WC	1,75	2,5	4,4		8,0	KK	50	KK	WD2
1.23	Pom. socjalne	13,64	3,0	40,9	4	3,0	130	130	N1	WD1
1.24	toaleta damska	8,33	2,5	20,8		4,0	KK	80	KK	WD6
1.25	toaleta męska	3,9	2,5	9,8		4,0	KK	KK	KK	KK
1.26	WC	1,37	2,5	3,4		7	KK	30	KK	WD6
1.27	WC	1,54	2,5	3,9		11,0	KK	50	KK	WD6
1.38	Dietetyk	13,77	2,7	37,2		2,5	110	110	N3	W3
1.39	Pom. Magazynowe	11,74	2,7	31,7		1,0	40	40	N3	WD3
1.45	Gabinet zabiegowy	14,23	3,0	42,7	2	5,0	210	200	N1	W1
1.46	Gabinet lekarski	14,2	3,0	42,6	2	2,5	110	110	N1	W1
	2 PIĘTRO									
2.18	Poradnia Anestozjologii	13,77	2,7	37,2		2,5	110	110	N3	W3
2.19	Pom. Magazynowe	12,03	2,7	32,5		1,0	40	40	N3	WD3
2.27	Gabinet lekarski	15,18	3,0	45,5	2	2,5	110	110	N1	W1
2.28	Gabinet lekarski	15,3	3,0	45,9	2	2,5	110	110	N1	W1
2.02	toaleta damska	8,33	2,5	20,8		4,0	KK	80	KK	WD6
2.03	toaleta męska	3,9	2,5	9,8		4,0	KK	KK	KK	KK
2.04	WC	1,37	2,5	3,4		7	KK	30	KK	WD6
2.05	WC	1,54	2,5	3,9		11,0	KK	50	KK	WD6

N1	W1	6530	5410
N2	W2	660	660
N3	W3	590	300
	WD1		320
	WD2		740
	WD3		160
	WD4		150
	WD5		215
	WD6		680